WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97966
Permit No.
Basin 045

NOTICE OF INTENT NO. 56163

1. OWNER RAY LAVOIE
MAILING ADDRESS 727 ROSE LANE
FERNLEY, NV 89408

ADDRESS AT WELL LOCATION RUBY RANCH DRIVE #1 LOT 9

2. LOCATION ____ 1/4 W1/2 1/4 Sec. 24 T 33N N/S R 57~~00~~ E ELKO County
PERMIT NO. ____ Issued by Water Resources | 089-001-009 Parcel No. | RUBY HOME RANCH #1 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other ____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SUB SOIL		0	6	6
ROCK & COBBLE		6	8	2
BROWN CLAY		8	12	4
SAND & GRAVEL		12	58	46
TAN COLORED CLAY		58	103	45
BLUE/GREEN CLAY		103	114	11
ROCK		114	125	11
TAN CLAY		125	177	52
HARD ROCK		177	178	1
BROWN CLAY		178	216	38
HARD FRACTURED ROCK	X	216	218	2
BROWN CLAY		218	266	48

Date started 10/15/2005 , 19__
Date completed 10/24/2005 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	75		8

8. WELL CONSTRUCTION
Depth Drilled 266 Feet Depth Cased 266 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	266	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	19
6	SDR-17		19	266

Perforations:
Type perforation SCREEN
Size perforation .050
From 240 feet to 266 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 53
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Bentonite 19 - 53
Gravel Packed: [X] Yes [ ] No
From 53 feet to 266 feet

9. WATER LEVEL
Static water level 134 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature COLD °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING CO. (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 10/28/2005

USE ADDITIONAL SHEETS IF NECESSARY