WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97976
Permit No.
Basin 045

NOTICE OF INTENT NO. 55111

1. OWNER ROBERT OLSON
MAILING ADDRESS P. O. BOX 281301
LAMOILLE, NV 89828

ADDRESS AT WELL LOCATION PARCEL A, WESTLUND DRIV

2. LOCATION NW 1/4 NE 1/4 Sec. 29 T 33N N/S R 58E E ELKO County
PERMIT NO. _____ Issued by Water Resources | 007-080-119 Parcel No. | SPECIAL LANDS Subdivision Name

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other_____

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
BLACK TOPSOIL		0	2	
BROWN GRAVEL & ROCK		2		
CONGLOMERATE			20	18
BROWN CLAY		20	35	15
BROWN CLAY W/GRAVEL		35		
LAYERS			80	45
BROWN SAND & GRAVEL	X	80	120	40

RECEIVED
2005 NOV -1 PM 12:03
STATE ENGINEERS OFFICE

Date started 9/19/2005, 19__
Date completed 9/20/2005, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
80		4

8. **WELL CONSTRUCTION**
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10-5/8 Inches	0 Feet	120 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+1	120

Perforations:
Type perforation MACHINE MILL SLOT
Size perforation 3/16 X 3, 6 ROW
From 100 feet to 120 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 120 feet

9. **WATER LEVEL**
Static water level 30 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. Contractor
Address P. O. BOX 850 Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1998
Signed Bradley D. Wiese By driller performing actual drilling on-site or contractor
Date 9/28/2005