WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97997
Permit No.
Basin 109

NOTICE OF INTENT NO. 50197

1. OWNER Santa Margarita Ranch
MAILING ADDRESS 136 E. Walker River
Yerington NV
ADDRESS AT WELL LOCATION Same

2. LOCATION NW ¼ NE ¼ Sec. 17 T. 10 N/S R. 27 E. Lyon Co. County
PERMIT NO. 49274 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE: [ ] Domestic [X] Irrigation [X] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE: [ ] Cable [X] Rotary [ ] RVC [X] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulder, Cobbles Gravel	✓	0	621'	621
Course Sand Gravel, Cobbles and Boulders	✓	621'	602	481

Date started April 25/03, 20
Date completed May 10/03, 20

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
test			
pump	1000+100	195'	10 Hrs

8. WELL CONSTRUCTION
Depth Drilled 602 Feet Depth Cased 602' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
test	12¼ Inches	0 Feet	602 Feet
Ream	23" Inches	0 Feet	602' Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"	42 lbs	.250	+1	602'

Perforations:
Type perforation Sawed
Size perforation 1/8 X 3" 3/16 X 3"
From 100' feet to 300' feet
From 340 feet to 400' feet
From 402 feet to 442 feet
From 462 feet to 482 feet
From 502 feet to 602 feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 602 feet

9. WATER LEVEL
Static water level 20' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address PO Box 599 (Contractor)
Silver Springs NV
Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 5/23/03