WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

# STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98000
Permit No.
Basin 087

NOTICE OF INTENT NO. 55394

1. OWNER Air National Guard
MAILING ADDRESS 1776 Air National Guard Way
Reno, NV 89502

ADDRESS AT WELL LOCATION 1776 Air National Guard Way Reno Well T-2

2. LOCATION SW 1/4 NE 1/4 Sec. 19 T 19N N/S R 20E E Washoe County
PERMIT NO. _____ Issued by Water Resources
15-210-31 Parcel No.
Subdivision Name

3. **WORK PERFORMED**
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. **PROPOSED USE**
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. **LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| On this date we abandoned a 2" x 14' well by pumping neat cement mixed 5.2 gallons of water per sack of cement. We then pumped using tremie pipe from the bottom to the top of the well. | | | | |

Date started 10/25/2005 , 19__
Date completed 10/25/2005 , 19__

7. **WELL TEST DATA**

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. **WELL CONSTRUCTION**
Depth Drilled 14 Feet Depth Cased 14 Feet

**HOLE DIAMETER (BIT SIZE)**

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | | SCH40 | 0 | 14 |
| | | | | |
| | | | | |

**Perforations:**
Type perforation
Size perforation
From 3 feet to 13 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 2 feet to 14 feet

9. **WATER LEVEL**
Static water level 6 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality Not tested

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2159
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 10/26/2005

USE ADDITIONAL SHEETS IF NECESSARY