

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54196

1. OWNER Sunshine Coast ADDRESS AT WELL LOCATION LOT #105 Santa Sophia Drive
 MAILING ADDRESS _____ 60, Santa Sophia Douglas County
 2. LOCATION NW 1/4 SE 1/4 Sec 27 T 11 N/S R 23 E 1/4
 PERMIT NO. 009-231-05 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BR CLAY		0	8	8
GRAVEL		8	20	12
GRAY MUSHY CLAY		20	100	80
BROWN SANDY CLAY		100	119	19
SMALL GRAVEL		119	124	5
BROWN CLAY		124	131	7
DG		131	135	4
MEDIUM GRAVEL		135	150	15
SANDY GRAY CLAY		150	170	20
GRAY CLAY & GRAVEL		170	200	

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>+1</u>	<u>20</u>
<u>6 5/8</u>	<u>4</u>	<u>SPR21</u>	<u>20</u>	<u>200</u>

Perforations:
 Type perforation GRINDER CUT
 Size perforation .045" X 4"
 From _____ feet to _____ feet
 From 180 feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 51 ft Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 51 feet to 200 feet

9. WATER LEVEL
 Static water level 28 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality CLEAR

Date started 18 OCT 05, 20 _____
 Date completed 18 OCT 05, 20 _____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25+</u>		<u>1.0</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BLAIN DRILLING & PUMP CO. INC.
P.O. Box 1235
Carson City, NV 89702
 Nevada contractor's license number issued by the State Contractor's Board 46498
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
 Signed Jack Watson
 By driller performing actual drilling on site or contractor
 Date 27 OCT 05