WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98035
Permit No.
Basin 066

NOTICE OF INTENT NO. 55936

1. OWNER ATNA RESOURCES
MAILING ADDRESS P.O. BOX 969
WINNEMUCCA, NV 89446-0969

ADDRESS AT WELL LOCATION PINSON MINE
20 MILES N/E OF GOLCONDA, NV
I-80 EXIT- 194 GOLCONDA, NV 89414

2. LOCATION SE ¼ SE ¼ Sec. 29 T. 38 N/S R. 42 E. HUMBOLDT County
PERMIT NO. 65629 Issued by Water Resources | 0712107 Parcel No. | N/A Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG WELL APW1

Material	Water Strata	From	To	Thickness
MODERATELY FRACTURED LIMESTONE	8.5'	0'	60'	60'
MAJORLY FRACTURED LIMESTONE		60'	630'	570'

RECEIVED 2005 OCT 17 PM 12:09 STATE ENGINEERS OFFICE

Date started JULY 9, 2005
Date completed SEPTEMBER 22, 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1,591	217.36	12

8. WELL CONSTRUCTION
Depth Drilled 630 Feet Depth Cased 620 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
36	Inches	0	Feet	40	Feet
28	Inches	40	Feet	624	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
18	70.59	.375	+2	620

Perforations:
Type perforation ROSCOE MOSS FUL-FLO
Size perforation 0.125
From 120 feet to 140 feet
From 160 feet to 180 feet
From 200 feet to 600 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100 FEET
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 611 feet

9. WATER LEVEL
Static water level 8.5 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature Ambient °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MICHAEL HASLAM
Contractor
Address 11001 ETIWANDA AVE
Contractor
FONTANA, CA 92337
Nevada contractor's license number issued by the State Contractor's Board 0019101
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1660
Signed M Hal
By driller performing actual drilling on site or contractor
Date 10/10/05

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627