WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98037
Permit No.
Basin 104

NOTICE OF INTENT NO. 52800

1. OWNER Black Eagle Consulting
MAILING ADDRESS 1345 Capitol Blvd Ste A
Reno, Nv. 89502

ADDRESS AT WELL LOCATION Arthur St + Silver Sage Drive

2. LOCATION NW ¼ SW ¼ Sec. 32 T. 15 N/S R. 20 E. Carson City County

PERMIT NO. M/O-1377 (Issued by Water Resources) | 009-222-01 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty sand - yellow brown		0	13	13'
silty sand - reddish brown	↑	13	23	10'
silty sand - grey brown		23	33	10'
silty sand - brown yellow		33	36	3'
Silty sand - grey white	2	36	38	2'
sand w/silt + gravel - grey black	✓	38	41	3'
clayey sand - brown		41	43	2'
silty sand - red brown		43	46	3'
silty sand - yellow brown		46	53	7'
sand + silt - black		53	56	3'
silty sand - yellow brown	3	56	58	2'
sand + silt - grey brown		58	63	5'
silty sand - reddish brown	✓	63	65	2'

RECEIVED
2005 OCT 17 PM 12:06
STATE ENGINEERS OFFICE

Date started Aug 18, 20 05
Date completed Aug 18, 20 05

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 65 Feet Depth Cased 65.0 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		SCH 40	+3	50'

Perforations:
Type perforation Factory Slot
Size perforation 0.20
From 50 feet to 65' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-48'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
bentonite seal 46-48'
Gravel Packed: ☑ Yes ☐ No
From 48 feet to 65' feet

9. WATER LEVEL
Static water level 54' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 78.5 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Haz Tech Drilling (Contractor)
Address P.O Box 940 (Contractor)
Meridian Id 83680
Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1803-17
Signed (By driller performing actual drilling on site or contractor)
Date Sept 2 05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627