

OFFICE USE ONLY
 Log No. 98038
 Permit No. _____
 Basin 04

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52802

1. OWNER Black Eagle Consulting Inc ADDRESS AT WELL LOCATION Arthur St at
 MAILING ADDRESS 1345 Capital Blvd Ste A Horatio St
Renov, Nv. 89502

2. LOCATION NE 1/4 SE 1/4 Sec 31 T. 15 N. R. 20 E Carson City County
 PERMIT NO. M/0-1377 009-305-06 Parcel No. Subdivision Name

Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silty sand - brown	↑	0	3	3'
sand + silt - yellow brown	↑	3	8	5'
sand + silt - tan	↑	8	18	10'
sand + silt - grey red	↑	18	22	4'
sand + silt - brown red	↑	22	28	6'
sand + silt - tan yellow	↑	28	33	5'
sand + silt - red brown	↑	33	38	5'
sand + silt - tan	↑	38	40	2'
Silty sand - yellow brown	↑	40	43	3'
Silty sand - grey - red brown	↑	43	48	5'
Silty sand - reddish brown	↑	48	68	20'
Sand + silt - reddish brown	↑	68	76	8'
Silt + sand - brown tan red	↑	76	78	2'
Silty sand - brown grey	↑	78	81	3'
Sand + silt - brown greyish tan	↑	81	85'	4'

8. WELL CONSTRUCTION
 Depth Drilled 85 Feet Depth Cased 85 Feet

HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 8.5 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SC40	0+3	70

Perforations:
 Type perforation Factory Slot
 Size perforation 0.20
 From 70 feet to 85 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 0-68' Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured Grout
benzoin seal 66-68'

Gravel Packed: Yes No
 From 68 feet to 85 feet

9. WATER LEVEL
 Static water level 74' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 78.5° °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Haz Tech Drilling Contractor
 Address P.O. Box 940 Contractor
Mendham Il 63080
 Nevada contractor's license number issued by the State Contractor's Board 0038018
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1803 I-T
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date Sept 2 05

Date started Aug 16, 2005
 Date completed Aug 17, 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

RECEIVED
 2005 OCT 17 PM 12:06
 STATE ENGINEERS OFFICE