WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98043
Permit No.
Basin 105

NOTICE OF INTENT NO. 55336

1. OWNER Steve & Karen Sullivan
MAILING ADDRESS 2655 Stetson
Minden, NV 89423

ADDRESS AT WELL LOCATION 1594 Saratoga Ct. Minden

2. LOCATION NE 1/4 SE 1/4 Sec. 27 T 14N N/S R 20E E Douglas County
PERMIT NO. Issued by Water Resources | 1420-27-701-047 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	20	20
Sand broken rock		20	40	20
Compact DG	x	40	260	220
Compact DG broken rock	x	260	298	38

RECEIVED
2005 OCT 10 AM 9:58
STATE ENGINEERS OFFICE

Date started 9/22/2005 , 19__
Date completed 9/26/2005 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+		3

8. WELL CONSTRUCTION
Depth Drilled 298 Feet Depth Cased 298 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	298	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	298

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 238 feet to 298 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 298 feet

9. WATER LEVEL
Static water level 159 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 9/27/2005

USE ADDITIONAL SHEETS IF NECESSARY