



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 55748

1. OWNER Newmont ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS PO Box 388
Valmy, NV 89438
 2. LOCATION NW 1/4 NE 1/4 Sec 2 T 33 N S R 51 E Eureka County
 PERMIT NO. 56838, R-499, R499A Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>LY-61 HOLE#</u>	<u>Angle well</u>			
<u>Drilled with casing advancement system then perforated</u>				
<u>SANDSTONE</u>		<u>0</u>	<u>35</u>	<u>35</u>
<u>GRAVEL</u>		<u>35</u>	<u>55</u>	<u>20</u>
<u>SILTS</u>		<u>55</u>	<u>95</u>	<u>40</u>
<u>GRAVEL</u>		<u>95</u>	<u>100</u>	<u>5</u>
<u>SILTS</u>		<u>100</u>	<u>155</u>	<u>55</u>
<u>CLAY</u>		<u>155</u>	<u>160</u>	<u>5</u>
<u>SILTS</u>		<u>160</u>	<u>240</u>	<u>80</u>
<u>TUFF</u>		<u>240</u>	<u>280</u>	<u>20</u>
<u>GRAVEL</u>		<u>280</u>	<u>285</u>	<u>5</u>
<u>TUFF</u>		<u>285</u>	<u>300</u>	<u>15</u>
<u>CLAY</u>		<u>300</u>	<u>325</u>	<u>25</u>
<u>CLAY</u>		<u>325</u>	<u>335</u>	<u>10</u>
<u>RED CLAY</u>		<u>335</u>	<u>345</u>	<u>10</u>
<u>SILTSTONE</u>		<u>345</u>	<u>545</u>	<u>200</u>

8. WELL CONSTRUCTION
 Depth Drilled 545 Feet Depth Cased 315 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches 0 Feet 315 Feet
6 3/4 Inches 315 Feet 545 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10"</u>		<u>3/16</u>	<u>72</u>	<u>315</u>

Perforations:
 Type perforation vertical slot
 Size perforation 1/4" x 1"
 From BLANK 315 feet to 298 feet
 From perforated 298 feet to 268 feet
 From BLANK 268 feet to 55 feet
 From perforated 55 feet to 35 feet
 From BLANK 35 feet to 72 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level N/A feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 9-20, 2005
 Date completed 9-26, 2005

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>3</u>	<u>N/A</u>	<u>1/2 HR.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EKLUND Drilling Co Contractor
 Address 605 UNION PACIFIC WAY Contractor
EIKO NV
 Nevada contractor's license number issued by the State Contractor's Board 0030823
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1942
 Signed William Riley
 By driller performing actual drilling on site or contractor
 Date 10-13-05