COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98048
Permit No. 64425
Basin 162

NOTICE OF INTENT NO. 29116

1. OWNER CHRISTI,LLC PANNEE MCMACKIN
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3451 E TILLMAN ST
PAHRUMP, NV
GPS:

2. LOCATION SE ¼ SW ¼ Sec 31 T 21 S R 54 E NYE County

PERMIT NO. 64425 (Issued by Water Resources) | 45-441-13 (APN) | CAL-VISTA SUBDIVISION (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	180	180
CALICHE		180	184	4
CLAY		184	224	40
CALICHE	WB	224	243	19
CLAY		243	286	43
CALICHE	WB	286	298	12
CLAY		298	324	26
LIMESTONE	WB	324	386	62
CLAY		386	400	14
GRAVEL	WB	400	440	40

DCNR/DWR
RECEIVED
JAN 4 - 2006
LAS VEGAS OFFICE

Date started 12/23, 20 05
Date completed 12/23, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 440 Feet Depth Cased 440 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
14.5 Inches	0 Feet	20 Feet
12 3/4 Inches	20 Feet	440 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12" STEEL	.250	33.38	0	20
8" STEEL	.188	16.94	20	440

Perforations:
Type perforation SAWCUT
Size perforation 5/16 X 3
From 260 feet to 280 feet
From 300 feet to 320 feet
From 340 feet to 360 feet
From 380 feet to 400 feet
From 420 feet to 440 feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☒ Poured ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No ☐ 30% Grout
From 50 feet to 440 feet

9. WATER LEVEL
Static water level _____ feet below land surface
Artesian flow _____ G.P.M _____ P.S.I
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. OF NEV, INC. (CONTRACTOR)
Address P.O. BOX 4220 (CONTRACTOR)
P|AHRUMP, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dia
By driller performing actual drilling on site or contractor
Date 12/29/05

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com