

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. **98052**  
 Permit No.  
 Basin **φ48**



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **55099**

1. OWNER **B & B INVESTMENTS**  
 MAILING ADDRESS **P. O. BOX 1900**  
**ELKO, NV 89803**

ADDRESS AT WELL LOCATION **LOT 6, BLK 45, ON**  
**MARSHALL AVE**  
 N/S R **55E** E **ELKO** County  
**LUCKY NUGGET #1** Subdivision Name  
 Issued by Water Resources | **027-045-006** Parcel No.

3. **WORK PERFORMED**  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. **PROPOSED USE**  
 Domestic  
 Municipal/Industrial

Irrigation  Test  Stock  
 Monitor

5. **WELL TYPE**  
 Rotary RVC  
 Cable  X Air  
 Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thick-ness
TOPSOIL		0	1	1
BROWN CALICHE		1	24	23
BROWN GRAVEL & ROCK		24	30	6
BROWN SILTSTONE		30	110	80
BROWN CONGLOMERATE		110	130	20
BROWN SILTSTONE FIRM		130	170	40
BROWN SILTSTONE SOFT	XX	170	220	50

8. **WELL CONSTRUCTION**

Depth Drilled **220** Feet Depth Cased **220** Feet

**HOLE DIAMETER (BIT SIZE)**

	From	To	
<b>10 5/8</b> Inches	0	220	Feet
Inches			Feet
Inches			Feet

**CASING SCHEDULE**

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6.625</b>	<b>13.</b>	<b>.188</b>	<b>+1</b>	<b>220</b>

**Perforations:**  
 Type perforation **MACHINE MILL SLOT**  
 Size perforation **1/8 X 3 INCH, 6 ROW**

From	feet to	
	<b>200</b>	<b>220</b> feet
From		feet to

Surface Seal:  Yes  No  
 Depth of Seal **50**  
 Placement Method:  Pumped  Poured  
 Seal Type:  Neat Cement  Cement Grout  Concrete Grout

Gravel Packed:  Yes  No  
 From **50** feet to **220** feet

Date started **7/1/2005**, 19\_\_  
 Date completed **7/6/2005**, 19\_\_

7. **WELL TEST DATA**

TEST METHOD:  Bailer  Pump  Air Lift  
 G.P.M. **20** Draw Down (Feet Below Static) **4 HRS** Time (Hours)

9. **WATER LEVEL**  
 Static water level **130** feet below land surface  
 Artesian flow  G.P.M.  P.S.I.  
 Water temperature **COLD** °F Quality

10. **DRILLER'S CERTIFICATION**  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **HACKWORTH DRILLING, INC** Contractor  
 Address **P.O. BOX 850** Contractor  
**ELKO, NV 89803**  
 Nevada contractor's license number issued by the State Contractor's Board **020582**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1998**  
 Signed *Bradley D. White*  
 By driller performing actual drilling on-site or contractor  
 Date **7/6/2005**