

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 55480

1. OWNER Jim Enloe ADDRESS AT WELL LOCATION .7 mi. up highway  
 MAILING ADDRESS P.O. Box 386 341 from jct. @ Highway 342 on  
Silver City, Nev. 89428 S. side of rd.

2. LOCATION NE 1/4 SW 1/4 Sec 9 T 16 N/S R 21 E Lyon County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Parcel No. APN #16-101-15 Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Brown Clg / Sand Layers</u>		<u>0</u>	<u>28</u>	<u>28'</u>
<u>Sand, Gravel, cobbles, clay</u>		<u>28</u>	<u>32</u>	<u>4</u>
<u>Grey Andesite</u>		<u>32</u>	<u>57</u>	<u>22'</u>
<u>Cemented Gravel</u>	<u>*</u>	<u>57</u>	<u>59</u>	<u>5'</u>
<u>Lt. Brown Clay / Rock</u>		<u>59</u>	<u>70</u>	<u>11'</u>
<u>Cemented Andesite Gravel / 60% clay</u>		<u>70</u>	<u>73</u>	<u>3'</u>
<u>Cemented Andesite Gravel</u>	<u>*</u>	<u>73</u>	<u>89</u>	<u>16'</u>
<u>Fractured Andesite</u>	<u>*</u>	<u>89</u>	<u>95</u>	<u>6'</u>
<u>Hard Dark Grey-Blue Andesite</u>		<u>95'</u>	<u>98'</u>	<u>3'</u>
<u>The Bottom of this casing has no shoe has casing guides and was not driven. It is open and OK to deepen if ever needed. JWE</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 98' Feet Depth Cased 98' Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 98' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>		<u>.188</u>	<u>+1</u>	<u>98'</u>

Perforations:  
 Type perforation Factory Milled  
 Size perforation 3/32  
 From 58' feet to 98' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 52', 52-55' Bentonite Chips  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 55' feet to 98' feet

9. WATER LEVEL  
 Static water level: 59' feet below land surface  
 Artesian flow No G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature Cool °F Quality Clear

Date started 6 - 27 2005  
 Date completed 7 - 27 2005

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>23</u>	<u>20</u>	<u>2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NA Contractor \_\_\_\_\_  
 Address NA Contractor \_\_\_\_\_  
Drilled for himself AC 12-20-05  
 Nevada contractor's license number \_\_\_\_\_  
 issued by the State Contractor's Board NA  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 794  
 Signed J. V. Cape  
 By driller performing actual drilling on site or contractor  
 Date 8-8-05