

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY

Log No. 98072
 Permit No. _____
 Basin 105



PRINT OR TYPE ONLY

1. OWNER **RICH HENDEE**
 MAILING ADDRESS **432 ESTALONA SANA CRUZ CZ, 95060**

NOTICE OF INTENT NO. **52318**
 ADDRESS AT WELL LOCATION **1910 TEDSON LN GARDNERVILLE, NV 89410**

2. LOCATION NW $\frac{1}{4}$ SE $\frac{1}{4}$ Sec 12 T 12 N R 20 E **DOUGLAS** County
 PERMIT NO. SW NE **1220-12-610-003**

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other **MUD**

6. LITHOLOGIC LOG

8. WELL CONSTRUCTION

Material	Water Strata	From	To	Thickness
BROWN CLAY		0	4	4
COURSE GRAVELS		4	26	22
BROWN SANDY CLAY		26	110	84
BROWN CLAY		110	162	52
SMALL GRAVELS		162	193	31
BROWN GUMMY CLAY		193	243	50
FRACTURED GRAVELS	XXX	243	280	37
Plugged by Well log 125050				
Replaced by Well log 125051				

Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet
0 Feet 280 Feet
0 Feet 0 Feet
0 Feet 0 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 sdr21	4.06	.216	20	280

Perforations:
 Type perforation **SAW CUT**
 Size perforation **3X3/32**
 From 240 feet to 280 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 55 feet to 280 feet

9. WATER LEVEL
 Static water level 110 feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **CAPITAL CITY WELL DRILLING**
 (CONTRACTOR)
 Address **20 KIT KAT DRIVE**
 (CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board **00055548**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2157**
 Signed Rich Hendee
 By driller performing actual drilling on site or contractor
 Date **8/2/05**

Date started 7/8, 20 05
 Date completed 7/12, 20 05

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>63</u>	<u>3 HRS</u>