COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98075
Permit No.
Basin 106

NOTICE OF INTENT NO. 52321

1. OWNER TROY GOINS
MAILING ADDRESS 1415 HWY 395 SOUTH
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 1415 HWY 395 SOUTH
GARDNERVILLE, NV 89410

2. LOCATION ~~NW~~ SW ¼ SE ¼ Sec 7 T 10 N R 22 E DOUGLAS County

PERMIT NO. Issued by Water Resources | Parcel No. 1022-07-002-017 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	3	3
COURSE VOLCANIC GRAVELS		3	76	73
DARK BROWN CLAY		76	86	10
BLACK SLATE		86	153	67
HARD VOLCANIC GRAVELS		153	201	48
VERY FRACTURED VOLCANIC GRAVELS	XXX	201	230	29

RECEIVED 05 AUG 19 PM 12:08 STATE ENGINEER'S OFFICE

Date started 6/30, 20 05
Date completed 7/5, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	45	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 230' Feet Depth Cased 230' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	100 Feet
9 7/8 Inches	100 Feet	230 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	10
6 5/8	4.06	.216	10	230

Perforations:
Type perforation SAW CUT
Size perforation 3X3/32
From 190 feet to 230 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 230 feet

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 85 feet below land surface
Artesian flow G.P.M 35 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 00055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed
By driller performing actual drilling on site or contractor
Date 7/27/05

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429