WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98092
Permit No.
Basin 102

I

NOTICE OF INTENT NO. 55798

1. OWNER (Cornerstone) ADDRESS AT WELL LOCATION 1410 West 9th St.
MAILING ADDRESS Silver Springs, NV 89429

2. LOCATION SW ¼ SE ¼ Sec. 18 T. 17 N/S R. 25 E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 17-263-14 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravels, Boulders		1	89	
Bedrock		89	176	
Some Fracture		176	184	
w/large Clay Seams				
Fractured		184	340	
Small Clay Seams				
Medium hardness		280	340	
Varied fractures				

RECEIVED 05 AUG 12 PM 1:59 STATE ENGINEER'S OFFICE

Date started 7/16/05, 20
Date completed 7/18/05, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
3-7 GPM.		6 hrs

8. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/8 Inches		1 Feet	50 Feet
8 3/4 Inches		50 Feet	300 Feet
6 Inches		300 Feet	340 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	1.88	1	20
6 5/8	PVC	SH 40	20	300
H.S	PVC	SH 40	300	340

Perforations:
Type perforation Machine Perf
Size perforation 3/16 x 4 x 4
From 260 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 340' feet

9. WATER LEVEL
Static water level 139' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jones Drilling Inc Contractor
Address P.O. 598 Contractor
SS, NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 18716
Signed By driller performing actual drilling on site or contractor
Date 8/8/05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627