COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98105
Permit No.
Basin 162

NOTICE OF INTENT NO. 28340

1. OWNER CHUCK LYTLE
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3150 S JAYCO
PAJRUMP, NV
GPS:

2. LOCATION NE ¼ NW ¼ Sec 31 T 20 S R 53 E NYE County

PERMIT NO. (Issued by Water Resources) | 36-493-03 (APN) | PAHRUMP VALLEY ESTATES (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| CLAY | | 0 | 106 | 106 |
| CALICHE | WB | 106 | 114 | 8 |
| CLAY | | 114 | 134 | 20 |
| CALICHE | WB | 134 | 141 | 7 |
| CLAY | | 141 | 176 | 35 |
| CALICHE | WB | 176 | 191 | 15 |
| CLAY | | 191 | 200 | 9 |

DCNR/DWR
RECEIVED
JAN 4 - 2006
LAS VEGAS OFFICE

Date started 12/20, 20 05
Date completed 12/20, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION

Depth Drilled 200 Feet, Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10.25 | Inches | 0 Feet | 200 Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | 3.63 | .250 | 0 | 200 |

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 140' feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☒ Poured ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No ☐ 30% Grout
From 50 feet to 20 feet 200 DSB

9. WATER LEVEL
Static water level 86 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. OF NEV, INC. (CONTRACTOR)
Address P.O. BOX 4220 (CONTRACTOR)
PAHRUMP, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dean
By driller performing actual drilling on site or contractor
Date 12/29/05


Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com