WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98117
Permit No.
Basin 162

NOTICE OF INTENT NO. 29125

1. OWNER TOM AUGUSTINE
MAILING ADDRESS 2310 E FORT CHURCHILL
PAHRUMP, NV

ADDRESS AT WELL LOCATION 2310 E FORT CHURCHILL

2. LOCATION SW 1/4 SW 1/4 Sec. 12 T 19S N/S R 53E E NYE County
PERMIT NO. (Issued by Water Resources) 27-218-17 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---|---|---|---|---|
| GRAVEL & CLAY | | 0 | 560 | 560 |
| GRAVEL | WB | 560 | 580 | 20 |
| CLAY & GRAVEL | | 580 | 600 | 20 |
| GRAVEL & SAND | WB | 600 | 720 | 120 |

DCNR/DWR
RECEIVED
DEC 16 2005
LAS VEGAS OFFICE

Date started 11/30/2005, 19__
Date completed 12/2/2005, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 720 Feet Depth Cased 720 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 12.25 | Inches | 0 | Feet | 60 | Feet |
| 7 5/8 | Inches | 60 | Feet | 720 | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8" | 16.94 | .188 | 0 | 60 |
| 4.5 | 2.36 | .248 | 60 | 720 |

Perforations:
Type perforation
Size perforation
From 620 feet to 720 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 720 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed (By driller performing actual drilling on-site or contractor)
Date 12/2/2005

USE ADDITIONAL SHEETS IF NECESSARY