WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98127
Permit No. 69196
Basin 162

NOTICE OF INTENT NO. 28338

OWNER MOUNTAIN FALLS GOLF COURSE
MAILING ADDRESS 4750 MT FALLS PARKWAY
PAHRUMP, NV

ADDRESS AT WELL LOCATION 4750 MT FALLS PARKWAY

2. LOCATION NE 1/4 SE 1/4 Sec. 5 T 21S N/S R 54E E NYE County
PERMIT NO. 69196 Issued by Water Resources 08B 45-021-26 Parcel No.
Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
PUMP BENTONITE EZ SEAL				
FROM 450 TO 65 FT.				
PUMP NEAT CEMENT FROM				
65 FT TO 6 FT. DIG				
AROUND CASING CUT OFF				
& BACK FILL WITH				
NATIVE SOIL				

DCNR/DWR
RECEIVED
DEC 22 2005
LAS VEGAS OFFICE

Date started 11/10/2005, 19__
Date completed 11/15/2005, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled EXISTING Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
EXISTING	Inches	Feet	Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10.75	28.04	.250	0	450

Perforations:
Type perforation MILLS KNIFE
Size perforation 1/4 X 2
From 50 feet to 450 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 450
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1428
Signed ____ (By driller performing actual drilling on-site or contractor)
Date 11/17/2005

USE ADDITIONAL SHEETS IF NECESSARY