

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 98135
 Permit No. _____
 Basin 102
 28943
 NOTICE OF INTENT NO. 25852

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER 12-3-14 Corp. LLC ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3461 E Zolin 3461 E. Zolin
Pahrump, NV 89048

2. LOCATION SW 1/4 SW 1/4 Sec. 8 T 21 N/S R 54 E Nye County
 PERMIT NO. 45-081-89
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	52	52
brown caleche		52	56	4
See next line	x	56	93	37
brown clay with caleche strings				
grey caleche	x	93	96	3
See next line	x	96	122	26
grey loam with grey caleche strings				
grey loam	x	122	136	14
See next line	x	136	200	64
brown loam with grey caleche strings				

DCNR/DWR
 RECEIVED

DEC 12 2005

LAS VEGAS OFFICE

Date started 2/23/05 2005
 Date completed 2/23/05 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.		Time (Hours)
	Bailer	Pump	
	Draw Down (Feet Below Static)	Air Lift	

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200+1 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
11 Inches 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	200

Perforations:
 Type perforation sawcut
 Size perforation .188
 From 180 feet to 200 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 65 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 5801 S. Homestead Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
 Signed _____
 By driller performing actual drilling on-site or contractor
 Date 3-20-05