

001506

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 98180
Permit No. _____
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28908

1. OWNER Ken Albright ADDRESS AT WELL LOCATION Las Vegas Wash
MAILING ADDRESS 1900 E Flamingo
Suite 255 Las Vegas, NV
2. LOCATION NW 1/4 SW 1/4 Sec 28 T. 21 N/S R. 63 E. Clark County
PERMIT NO. 160-28-301-001 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Pinkish-gray Clay</u>		<u>0</u>	<u>5'</u>	<u>5'</u>
<u>Light Brown Clay</u>		<u>5'</u>	<u>10'</u>	<u>5'</u>
<u>Reddish silty sand</u>		<u>10'</u>	<u>15'</u>	<u>5'</u>
<u>Pale brown gravel</u>		<u>15'</u>	<u>25'</u>	<u>10'</u>
<u>Pale yellow sandstone</u>		<u>25'</u>	<u>30'</u>	<u>5'</u>
<u>Olive sandstone</u>		<u>30'</u>	<u>35'</u>	<u>5'</u>
<u>Reddish claystone</u>		<u>35'</u>	<u>40'</u>	<u>5'</u>
<u>Reddish brown siltstone</u>		<u>40'</u>	<u>45'</u>	<u>5'</u>
<u>Pale brown lime stone</u>		<u>45'</u>	<u>53'</u>	<u>8'</u>

8. WELL CONSTRUCTION
Depth Drilled 53 Feet Depth Cased 53 Feet
HOLE DIAMETER (BIT SIZE)
From 8.5 Inches To 0 Feet 53 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
2.5 _____ Sch 40 PUC 0 53
Perforations:
Type perforation Machine slotted
Size perforation 0.020
From 53 feet to 43 feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type:
Depth of Seal 38 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 53 feet to 40 feet

DCNR/DWR
RECEIVED

DEC 8 - 2005

LAS VEGAS OFFICE

9. WATER LEVEL
Static water level 32 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality Good

Date started 07/26, 2005
Date completed 07/26, 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services LLC Contractor
Address 7150 Placid Las Vegas, NV Contractor
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2193
Signed Victor Plas
By driller performing actual drilling on site or contractor
Date 12/06/05

110