REPORT NO. A05.072

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 98208
PERMIT NO.
BASIN 083

NOTICE OF INTENT NO. 55566

1. OWNER Sean Kennedy c/o Tri-West Development, LLC
MAILING ADDRESS 813 W. Laird St. Tempe, AZ 85281

ADDRESS OF WELL 2620 Musket Rd.
Virginia City Highlands, NV 89421

2. WELL LOCATION NW 1/4 SE 1/4 SEC. 29 T 18N R 21 E Storey COUNTY

PERMIT NO ____ PARCEL NO 03-331-13 SUBDIVISION NAME ____

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Multi color vol rock w/ green clay		0	10	10
Dark blue/green hard volcanic rock		10	80	70
Hard multi color volcanic rock		80	120	40
Hard reddish volcanic rock and		120		
dark green large fractured vol rock		120	130	10
Multi color volcanic rock	x	130	175	45
Purple & maroon volcanic rock		175	200	25
Blue green vol rock w/ red specs		200	265	65
Solid lime green color clay w/		265		
some rock		265	278	13

RECEIVED 2005 AUG 18 PM 2:00 DIVISION OF WATER RESOURCES

Notes : Latitude: N39 degrees 23.590'
Longitude: W119 degrees 39.148'

Date Started 8/4/05 Date Completed 8/8/05

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	18		3 hours

8. WELL CONSTRUCTION

Depth Drilled 278 Depth Cased 278

HOLE DIAMETER (BIT SIZE)

10	Inches	0	Feet	50	Feet
8 1/2	Inches	50	Feet	278	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	278

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 238 Feet to 258 Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50
PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 278 Feet

9. WATER LEVEL
Static Water Level 140 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature cool F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 2189

Signed ____
By driller performing actual drilling on site or contractor

Dated August 8, 2005