REPORT NO. A05.070

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 98211
PERMIT NO.
BASIN 104

NOTICE OF INTENT NO. 55578

1. OWNER Ted Stokes c/o Gary Laack Construction
MAILING ADDRESS 100 Lewers Creek Rd. Carson City, NV 89704

ADDRESS OF WELL 4400 Kings Canyon Rd.
Carson City, NV 89704

2. WELL LOCATION ~~NE~~ NW 1/4 NE 1/4 SEC. 23 T 15N R 19 E Carson City COUNTY

PERMIT NO ____ PARCEL NO 07-071-02 SUBDIVISION NAME ____

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Dirt, clay, volcanic rock		0	5	5
Volcanic rock & dark brown clay		5	7	2
Gravels & boulders	x	7	70	63
Green clay & rock	x	70	100	30
Green clay & cobbles		100	220	120
Gray clay & rock		220	240	20
Green clay, green & black rock		240	262	22
Cobbles & green clay		262	320	58
Heavy green clay & black rock		320	370	50
Gray/green clay & black rock		370	390	20
Multi color rock, green clay,	x	390		
white/brown/gray clay	x	390	405	15
Hard white rock		405	418	13

Notes : 9.5 yards neat cement used from 10'-100' to seal off upper water.
Latitude: N39 degrees 9.25' Longitude: W119 degrees 48.916'

Date Started 7/20/05 Date Completed 8/4/05

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		3 hours

8. WELL CONSTRUCTION

Depth Drilled 418 Depth Cased 418

HOLE DIAMETER (BIT SIZE)

10 5/8	Inches	0	Feet	100	Feet
8 1/2	Inches	100	Feet	418	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	418

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 378 Feet to 398 Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 100
PLACEMENT METHOD: [X] Pumped [ ] Poured

SEAL TYPE:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 100 Feet to 418 Feet

9. WATER LEVEL
Static Water Level 105 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature cool F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 1981

Signed [signature]
By driller performing actual drilling on site or contractor

Dated August 4, 2005