STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98220
Permit No.
Basin 105

NOTICE OF INTENT NO. 56294

1. OWNER: Rocky Terrace Estates
MAILING ADDRESS: 1080 Centerville Lane, Gardnerville, NV 89410
ADDRESS AT WELL LOCATION: Gardnerville, NV

2. LOCATION: SW 1/4 SE Sec. 8 T 12 N/S R 20 E Douglas County
PERMIT NO. 71727 Issued By Water Resources
Parcel No.
Subdivision Name

3. WORK PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[x] Municipal/Indu [ ] Monitor [ ] Shock

5. WELL TYPE
[ ] Cable [ ] Rotary [x] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill dirt		0	2	2
Sand, gravel and cobbles		2	116	114
Clay w/coarse sand		116	119	3
Sand, gravel and cobles		119	148	29
Sand and gravel		148	160	12
Sand and gravel w/clay stringers		160	287	127
Clay w/sand layers		287	299	12
Sand & gravel w/clay layers		299	309	10
Sand & gravel w/hard rock		309	356	47
Sand & gravel-few cobbles		356	400	44
Sand & gravel, little clay		400	416	16

RECEIVED JUL 21 2005 WATER RESOURCES OFFICE

Date Started May 6 2005
Date Completed May 11 2005

7. WELL TEST DATA

TEST METHOD: [ ] BAILER [x] PUMP [ ] AIR LIFT

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pumping Level 149'	1000	121	24

8. WELL CONSTRUCTION
Depth Drilled 416 Feet Depth Cased 390 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
30	Inches	0	Feet	100	Feet
22	Inches	100	Feet	416	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (inches)	Weight (pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24		0.250	0	100
12 3/4		0.250	+2	390

Type Perforation: Wire Wrap
Size Perforation: 0.050
From 240 feet to 390 feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal: 100'
as per conv w/ Humboldt Drilling 7/23/08
Placement Method: [x] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [x] Cement Grout [ ] Concrete Grout

Gravel Packed: [x] Yes [ ] No
From 3 feet to 416 feet
From feet to feet

9. WATER LEVEL
Static Water Level 28 feet below land surface
Artesian flow NA G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name: Hydro Resources Nevada Inc. dba Humboldt Drilling and Pump Co.
Address: 4975 West Winnemucca Boulevard
Winnemucca, Nevada 89445

NV Contractor's LIC# issued by the State Contractor's Board	56797
NV Driller's LIC# issued by Div. of Water Resources, on-site driller	2177
Signed: C. Jaynes - Office	Date: 7/8/05