REPORT NO. A05.053

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 98251
PERMIT NO.
BASIN 083

NOTICE OF INTENT NO. 56274

1. OWNER W. Scott Winkler
MAILING ADDRESS 2190 Parkway Dr. Reno, NV 89502
ADDRESS OF WELL 21397 Delta Dr.
Virginia City Highlands, NV 89521

2. WELL LOCATION SW 1/4 NW 1/4 SEC. 32 T 18N R 21 E Storey COUNTY

PERMIT NO ____ PARCEL NO 03-015-18 SUBDIVISION NAME ____

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Purple & white rock		0	8	8
Purple rock & brown clay		8	12	4
Purple & white rock		12	15	3
Purple rock & gray clay		15	20	5
White & purple rock		20	35	15
Purple & white rock, purple clay		35	45	10
Green & yellow rock & brown clay		45	55	10
Purple/white/green/yellow rock		55	75	20
Gray & white rock & clay	x	75	105	30
Blue/green/white rock	x	105	160	55

RECEIVED 05 JUL 11 AM 10:37 STATE ENGINEERS OFFICE

Notes: Latitude: N39 degrees 23.066'
Longitude: W119 degrees 39.413'

Date Started 6/17/05 Date Completed 6/20/05

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		1 hour

8. WELL CONSTRUCTION
Depth Drilled 160 Depth Cased 160

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 160 Feet
____ Inches ____ Feet ____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	160

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 140 Feet to 160 Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50
PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 160 Feet

9. WATER LEVEL
Static Water Level 70 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature cool F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.
Name Aqua Drilling & Well Service Inc.
Address 675 Edison Way
Reno, NV 89502
NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 1981
Signed [signature]
By driller performing actual drilling on site of contractor
Dated June 20, 2005