WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98253
Permit No.
Basin 176

NOTICE OF INTENT NO. 56155

. OWNER SANDRA STONIER
MAILING ADDRESS 3199 SCENIC VIEW
ELKO, NV 89801

ADDRESS AT WELL LOCATION RUBY VALLEY

2. LOCATION SW 1/4 SW 1/4 Sec. 2 T 31N N/S R 59E E ELKO County
PERMIT NO. (Issued by Water Resources) 007-280-027 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	4	4
STICKY CREAM COLORED		4		
CLAY			46	42
BROWN CLAY		46	51	5
BLOND CLAY		51	84	33
BLUE CLAY		84	123	39
SAND & GRAVEL	X	123	125	2
HARD ROCK		125	142	17
BROKEN FRACTURED ROCK	X	142	160	18

RECEIVED 05 JUL 18 PM 2:10 STATE ENGINEER'S OFFICE

Date started 6/30/2005, 19__
Date completed 7/6/2005, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	45		5

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	160 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	18
6	SDR-17		18	160

Perforations:
Type perforation SCREEN
Size perforation .050
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NEVADA 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed Sharel C. Fertig (By driller performing actual drilling on-site of contractor)
Date 7/15/2005

USE ADDITIONAL SHEETS IF NECESSARY