WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98259
Permit No.
Basin 047

NOTICE OF INTENT NO. 55268

OWNER PARIS LIVESTOCK
MAILING ADDRESS HC 30 BOX 320
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION SOUTH OF ELKO ON HIGHWAY 46

2. LOCATION SE 1/4 SE 1/4 Sec. 34 T 31N N/S R 56E E ELKO County
PERMIT NO. Issued by Water Resources
06-270-02 Parcel No.
Subdivision Name

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
LOAM		0	6	6
CALICHI CLAY		6	23	17
SAND & GRAVEL	X	23	24	1
CALICHI CLAY		24	98	74
SAND & GRAVEL	X	98	118	20

RECEIVED 05 JUL 18 PM 2:10 WATER RESOURCES OFFICE

Date started 7/7/2005, 19__
Date completed 7/11/2005, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	125		6.5

8. **WELL CONSTRUCTION**
Depth Drilled 118 Feet Depth Cased 118 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	118	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	18
6	SDR.17		18	118

Perforations:
Type perforation SCREEN
Size perforation .050
From 98 feet to 118 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 52
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Bentonite 22-51
Gravel Packed: [X] Yes [ ] No
From 52 feet to 118 feet

9. **WATER LEVEL**
Static water level 16 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING
Contractor
Address P.O. BOX 525
Contractor
ELKO, NEVADA 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed
By driller performing actual drilling on-site or contractor
Date 7/15/2005

USE ADDITIONAL SHEETS IF NECESSARY