WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98255
Permit No.
Basin Ø48

NOTICE OF INTENT NO. 56154

OWNER JOHN & AMY BOYKIN
MAILING ADDRESS 197 WESTERN HILLS
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION ~~197 WESTERN WILLS #12~~
860 Meadow View Dr

2. LOCATION NE 1/4 NE 1/4 Sec. 3 T 32N N/S R 55E E ELKO County
PERMIT NO. (Issued by Water Resources) 077-010-019 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC [X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LOAM		0	2	2
CALICHI CLAY		2	172	170
BROCKEN FRACTURED ROCK	X	172	184	12
HARD ROCK		184	210	26
SANDSTONE		210	215	5
BROKEN FRACTURED ROCK	X	215	223	8

RECEIVED 05 JUL 18 PM 2:10 WATER RESOURCES OFFICE

Date started 6/23/2005 , 19__
Date completed 6/27/2005 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	15		4.5

8. WELL CONSTRUCTION
Depth Drilled 223 Feet Depth Cased 223 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	223	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	23
6	SDR-17		23	223

Perforations:
Type perforation SCREEN
Size perforation .050
From 203 feet to 223 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 51
Placement Method: [X] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Bentonite 22-51
Gravel Packed: [X] Yes [ ] No
From 51 feet to 223 feet

9. WATER LEVEL
Static water level 170 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NEVADA 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on-site or contractor)
Date 7/15/2005

USE ADDITIONAL SHEETS IF NECESSARY