

OFFICE USE ONLY
 Log No. 98256
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52271

1. OWNER John Fent ADDRESS AT WELL LOCATION 1724 TEDSON
 MAILING ADDRESS _____
 2. LOCATION SW ^{NE} 1/4 ~~1/4~~ Sec. 12 T. 12 N/S R. 20 E Douglas County
 PERMIT NO. 1220-12-610-001 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DIRT-ROCK		0	18	18
COBBLES		18	38	20
BROWN CLAY		38	44	6
BR CLAY - GRAVEL		44	140	96
BR STICKY CLAY		140	210	70
BR CLAY - GRAVEL		210	246	36
GRAVEL		246	280	34

8. WELL CONSTRUCTION
 Depth Drilled 280 Feet Depth Cased 280 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
11 Inches _____ Feet 50 Feet
9 7/8 Inches 50 Feet 280 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>1.188</u>	<u>+1</u>	<u>20</u>
<u>6 5/8</u>	<u>4</u>	<u>SDR21</u>	<u>20</u>	<u>280</u>

RECEIVED
 05 JUL 18 PM 2:26
 STATE DRILLERS OFFICE

Perforations:
 Type perforation GRINDER CUT
 Size perforation 0.45 x 4"
 From _____ feet to _____ feet
 From 240 feet to 280 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 51 FT Neat Cement
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From 51 feet to 280 feet

Date started 3 Jun 2005
 Date completed 6 Jun 2005

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20-22</u>		<u>2.5</u>

9. WATER LEVEL
 Static water level 74 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BLAIN DRILLING & PUMP CO. INC.
 Address P.O. Box 1255 Carson City, NV 89702
 Nevada contractor's license number issued by the State Contractor's Board 46498
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
 Signed Jack Dotson
 By driller performing actual drilling on site or contractor
 Date 7 JUN 05