

OFFICE USE ONLY
 Log No. 98258
 Permit No. _____
 Basin 107

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54118

1. OWNER Ray LERG ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____ #62 DESERT VIEW

2. LOCATION NE 1/4 SW 1/4 Sec 15 T. 11 N/S R. 24 E. LYON County
 PERMIT NO. _____ Issued by Water Resources 9-172-06 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND-GRAVEL		0	20	
BROWN CLAY		20	55	
GRAY CLAY		55	85	
BROWN CLAY		85	90	
SANDY GRAVEL	X	90	110	
DR STICKY CLAY		110	122	
SANDY GRAVEL	X	122	150	
LARGE GRAVEL	X	150	165	
SANDY GRAVEL	X	165	180	

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>14</u>	<u>.188</u>	<u>+1</u>	<u>20</u>
<u>6 3/8</u>	<u>4</u>	<u>SDR21</u>	<u>20</u>	<u>180</u>

Perforations:
 Type perforation GRINDER CUT
 Size perforation 1045" X 4"

From _____ feet to _____ feet
 From 160 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 52 ft
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 52 feet to 180 feet

Date started 20 JUN 2005
 Date completed 21 JUN 2005

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20-22</u>		<u>1.5</u>

9. WATER LEVEL
 Static water level 64 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality TINT OF BROWN

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BLAIN DRILLING & PUMP CO. INC.
 P.O. Box 1255
 Address Carson City, NV 89702
 Contractor

Nevada contractor's license number issued by the State Contractor's Board 46498
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167

Signed Jack Dotson
 By driller performing actual drilling on site or contractor
 Date 21 JUN 05

RECEIVED
 JUL 18 PM 2:26
 STATE ENGINEER'S OFFICE