



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54119  
52272

1. OWNER KEN - Sauter Development ADDRESS AT WELL LOCATION #50 HAWK VIEW Smith Valley, NV  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 SE 1/4 Sec 9-132-11 T. 11 N/S R. 23 E County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. 13 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	18	18
BR CLAY		18	41	23
BR SANDY CLAY		41	130	89
BLACK CLAY	<del>X</del>	130	296	166
BR CLAY		296	302	6
DG-GREEN	<del>X</del>	302	340	38

RECEIVED  
 05 JUL 18 PM 2:26  
 DIVISION OF WATER RESOURCES OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 340 Feet Depth Cased 340 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 0 Feet 340 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	14	1.88	+1	20
6 5/8	4	SDR21	20	340

Perforations:  
 Type perforation GRINDER CUT  
 Size perforation 1045" x 4"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 300 feet to 340 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 56 ft  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 56 feet to 340 feet

Date started 8 JUN 05  
 Date completed 13 JUN 2005

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>257</u>		<u>2.5</u>

9. WATER LEVEL  
 Static water level 76 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. PSI  
 Water temperature COLD °F Quality CLEAR w/ROCK

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name BLAIN DRILLING & PUMP CO. INC.  
 Address PO Box 1255 Carson City, NV 89702  
 Nevada contractor's license number issued by the State Contractor's Board 46498  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167  
 Signed Jack Dotson  
 By driller performing actual drilling on site or contractor  
 Date 16 JUN 05