COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98266
Permit No.
Basin 105

NOTICE OF INTENT NO. 52322

1. OWNER KATSARIS CONSTRUCTION
MAILING ADDRESS 2991 HOT SPRINGS RD
MINDEN, NV 89423

ADDRESS AT WELL LOCATION 1871 COLT DR
GARDNERVILLE, NV 89410

2. LOCATION ~~NE~~ ¼ ~~SW~~ ¼ Sec 24 T 12 N R 20 E DOUGLAS County
PERMIT NO. SE NW (Issued by Water Resources) | 1220-24-201-038 (Parcel No.) | RHUENSTROTH SUBDIVISION (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HARDPAN CLAY		0	5	5
COURSE SANDS AND BROWN CLAY		5	16	9
COURSE GRAVELS		16	21	5
BROWN CLAY		21	45	24
LARGE GRAVELS		45	119	84
COURSE GRAVELS VOLCANIC SANDS		119	165	46
LARGE FRACTURED GRAVELS	XXX	165	205	40

RECEIVED 05 JUL 29 AM 1:34 WATER RESOURCES OFFICE

Date started 7/5, 20 05
Date completed 7/7, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	40	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 205 Feet Depth Cased 205 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	100 Feet
9 7/8 Inches	100 Feet	205 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	25
6 5/8 sdr 21	4.06	.216	25	205

Perforations:
Type perforation SAW SLOT
Size perforation 3 X 3/32
From 165 feet to 205 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55'
Placement Method: ☐ Pumped ☒ Poured
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 205 feet

Seal Type:
☒ Neat Cement
☒ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M 30 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane (By driller performing actual drilling on site or contractor)
Date 7/9/05