

OFFICE USE ONLY
 Log No. 98275
 Permit No. _____
 Basin 031

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56282
302 Bottle creek Rd

1. OWNER Chuck Giordano
 MAILING ADDRESS 302 Bottle creek Rd
Winnemucca NV. 89445
 ADDRESS AT WELL LOCATION _____
 2. LOCATION SE 1/4 SE 1/4 Sec. 11 T H0 N/S R 33 E Humbolt County
 PERMIT NO. 27786
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	10	
CLAY & SAND		10	20	
SOFT CLAY		20	38	
FINE BLK SAND		38	41	
CONSLD SAND & GRAVEL / CLAY		41	70	
BLK CLAY / SOFT		70	75	
BRN SILTY CLAY		75	80	
SAND & GRAVEL W CLAY		80	100	
BRN CLAY		100	130	
GRY CLAY		130	150	
SAND & GRAVEL		150	180	
SOFT BRN CLAY / SAND		180	230	
SAND & GRAVEL		230	300	
COBBLES / SAND & GRAVEL		300	400	

8. WELL CONSTRUCTION
 Depth Drilled 410 Feet Depth Cased 400 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 50 Feet
36 Inches 0 Feet 50 Feet
26 Inches 50 Feet 410 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>16</u>		<u>.250</u>	<u>42</u>	<u>400</u>

 Perforations:
 Type perforation Double Row Well slot
 Size perforation 1/4"
 From 80' feet to 400' feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 0 feet to 410 feet

9. WATER LEVEL
 Static water level 40' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started JUNE 6 2005, 19____
 Date completed JUNE 8 2005, 19____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ANIS Enterprises Contractor
 Address 399 Denio Hwy 140 Contractor
Winnemucca NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 0058683
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2140
 Signed Ralph C. Schab
 By driller performing actual drilling on site or contractor
 Date 6-28-05

RECEIVED
 05 JUN 30 AM 11:02
 STATE ENGINEER'S OFFICE