


STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT



office use only  
Log No. **98277**  
Permit No. \_\_\_\_\_  
Basin **083**

NOTICE OF INTENT NO **66069**  
**2000 Morgan Rd**

1. OWNER **Janet Fisher** ADDRESS AT WELL LOCATION  
ILING ADDRESS **2000 Morgan Rd**  
**Virginia City Highlands**

2. Location **SE 1/4 SE 1/4 Sec 32 T 18 N R 21E** Storey County  
PERMIT NO. \_\_\_\_\_ PARCEL NO. **03-111-26** SUBDIVISION NAME \_\_\_\_\_

| 3. WORK PERFORMED                            |         |             | 4. PROPOSED USE                              |            |       | 5. WELL TYPE                            |  |     |
|--|---------|-------------|--|------------|-------|---|--|-----|
| <input checked="" type="checkbox"/> New Well | Replace | Recondition | <input checked="" type="checkbox"/> Domestic | Irrigation | Test  | Cable                                   | <input checked="" type="checkbox"/> Rotary | RVC |
| Deepen                                       | Abandon | Other       | Municipal/Industrial                         | Monitor    | Stock | <input checked="" type="checkbox"/> Air | Other                                      | Mud |

6. LITHOLOGIC LOG

| Material                   | Water Strata | From | To  | Thickness |
|----------------------------|--------------|------|-----|-----------|
| Tan Rock.                  |              | 0    | 120 | 120       |
| Broken brown & green rock. |              | 120  | 135 | 15        |
| White purple rock.         |              | 135  | 185 | 50        |
| Broken white purple rock.  |              | 185  | 240 | 55        |
| Brown & green rock.        |              | 240  | 340 | 100       |
| Broken brown & green rock. |              | 340  | 374 | 34        |
| Broken granite.            |              | 375  | 480 | 105       |
| DG                         |              | 480  | 775 | 295       |

8. WELL CONSTRUCTION

| Depth Drilled |        | Depth Cased |      | HOLE DIAMETER (BIT SIZE) |      |
|---------------|--------|-------------|------|--------------------------|------|
| From          | To     | From        | To   | From                     | To   |
| 10 5/8        | inches | 0           | feet | 50                       | feet |
| 8 3/4         | inches | 50          | feet | 374                      | feet |
| 6 1/8         | inches | 374         | feet | 775                      | feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8              | 12.94               | 188                     | +1 1/2      | 775       |

Perf 441 to 461  
Perf 481 to 501  
Perf 521 to 541  
Perf 561 to 581  
Perf 601 to 621  
Perf 641 to 661  
Perf 681 to 701  
Perf 715 to 775

Perforations::

| Type Perforation          | Factory   |
|---------------------------|-----------|
| Size perforation          | 3/32 x 3" |
| From 164 feet to 184 feet |           |
| From 244 feet to 264 feet |           |
| From 334 feet to 374 feet |           |
| From 361 feet to 381 feet |           |
| From 401 feet to 421 feet |           |

Surface Seal  YES No Seal Type:  
Depth of Seal 50 feet Neat Cement  
Pumped  X Poured  Concrete Grout  
Gravel Packed:  Yes No  
From 50 feet to 374 feet

9. WATER LEVEL

Static water level 120 feet below land surface  
Artesian flow 0 GPM 0 P.S.I.  
Water Temperature cold Degrees F Quality

Date started **9-2 -05**  
Date completed **10-18 -05**

7. WELL TEST DATA

| TEST METHOD: | Bailer                        | Pump         | x | Air Lift |
|--------------|-------------------------------|--------------|---|----------|
| G.P.M.       | Draw Down (Feet Below Static) | Time (hours) |   |          |
| 10           | 420                           |              |   |          |
| 12           | 520                           |              |   |          |
| 15           | 580                           |              |   |          |

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **McKay Drilling, Inc.**  
**2290 Pioneer Drive**  
**Reno, NV 89509**

NV Contractors No. **14170**  
NV Driller's Lic (on site) **2236**

Signed *Steve McKay*  
By driller performing actual drilling on site or contractor

Date **10-19 -05**