

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 98283  
 Permit No. \_\_\_\_\_  
 Basin 105  
 NOTICE OF INTENT NO. 54341

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **GREG DAVIES CONSTRUCTION** ADDRESS AT WELL LOCATION **1466 RABBITBRUSH GARDNERVILLE, NV 89410**  
 MAILING ADDRESS **P.O. BOX 22 GARDNERVILLE, NV 89410**

2. LOCATION ~~SW~~ 1/4 ~~NE~~ 1/4 Sec 36 T 13 N R 20 E DOUGLAS County  
 PERMIT NO. NIC 8W 1320-36-02-005

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 Issued by Water Resources Parcel No. 051 Subdivision Name \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVBERBURDEN		0	4	4
BROWN CLAY AND GRAVELS		4	56	52
BROWN CLAY SANDY		56	186	130
BROWN CLAY		186	225	39
LOSS CIRR		225		
SMALL OBSIDIAN SANDS		225	236	9
BROWN CLAY		236	341	105
GRAY CLAY		341	452	111
GRAY CLAY WITH SANDY AREAS	XX			
COURSE GRAVELS		452	500	48

8. WELL CONSTRUCTION

Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>11</u> Inches	<u>0</u> Feet <u>340</u> Feet
<u>9 7/8</u> Inches	<u>340</u> Feet <u>500</u> Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>500</u>

Perforations:  
 Type perforation FACTORY MILL SLOT  
 Size perforation 3 X 3/32

From	To
<u>440</u> feet to	<u>460</u> feet
_____ feet to	_____ feet
<u>480</u> feet to	<u>500</u> feet
_____ feet to	_____ feet
_____ feet to	_____ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 500 feet

Date started 11/11, 20 05  
 Date completed 11/16, 20 05

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>115</u>	<u>3 HRS</u>

9. WATER LEVEL  
 Static water level 235 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25 P.S.I.  
 Water temperature WARM °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name CAPITAL CITY WELL DRILLIG (CONTRACTOR)  
 Address 20 KIT KAT DRIVE (CONTRACTOR)  
CARSON CITY, NV 89706  
 Nevada contractor's license number issued by the State Contractor's Board 0055548  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157  
 Signed Rick Crane  
 By driller performing actual drilling on site or contractor  
 Date 11/20/05