COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98342
Permit No.
Basin 071

NOTICE OF INTENT NO. 55641

1. OWNER Steve and Cindy Jones
MAILING ADDRESS 7120 Torrey Lane
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION ~~7120~~ Torrey Lane
Winnemucca, NV 89445 7100

2. LOCATION NW ¼ NW ¼ Sec 18 T 35 N R 38 E Humboldt County

PERMIT NO. (Issued by Water Resources) | 010-611-12 (Parcel No) | Tycana subdivision (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	3
Gravel		3	15	12
Boulders		15	22	7
Cobles and Gravel		22	58	36
Rock ledge		58	60	2
Boulders		60	85	25
Sand and gravel		85	90	5
Cobles		90	130	40
Boulders		130	140	10
Gravel		140	143	3
Boulders		143	160	17
Sand and gravel		160	165	5
Boulders		165	195	30
Cobles and gravel		195	220	5
Boulders		220	235	15
Cobles and gravel		235	245	10
Boulders		245	252	7

Date started July 5, 20 05
Date completed July 7, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		4

8. WELL CONSTRUCTION

Depth Drilled 251 Feet Depth Cased 246 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	252 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	10	.188	+1	10
6.625	4	.316	10	206

Perforations:
Type perforation screen
Size perforation .050
From 206 feet to 246 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 57
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 57 feet to 246 feet

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 170 feet below land surface
Artesian flow N/A G.P.M N/A P.S.I
Water temperature Cool °F Quality Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson & Sons Drilling, Inc. (CONTRACTOR)
Address 10760 Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed [signature] By driller performing actual drilling on site or contractor
Date July 13,2005

RECEIVED 2005 JUL 21 AM 10:58 DIVISION OF WATER RESOURCES

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com