COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98345
Permit No.
Basin 101
NOTICE OF INTENT NO. [redacted] 53111

1. OWNER JESSEE & MICHELLE MELENDY
MAILING ADDRESS 2395 LUCAS
FALLON, NV 89406

ADDRESS AT WELL LOCATION 2395 LUCAS
FALLON, NV 89406

2. LOCATION SW ¼ NE ¼ Sec 13 T 19 N R 27 E CHURCHILL County

PERMIT NO. (Issued by Water Resources) 007-101-28 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SAND		1	10	9
BROWN CLAY		10	30	20
BROWN SAND		30	40	10
GRAY SAND		40	60	20
BLACK SILT/CLAY		60	90	30
GRAY SAND		90	100	10
GRAY CLAY		100	103	3
BROWN SANDS & GRAVEL		103	114	11

RECEIVED 05 JUL 19 AM 11:45 WATER RESOURCES OFFICE

Date started MAY 18, 20 2005
Date completed JUNE 18, 20 2005

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
22		1 HR

8. WELL CONSTRUCTION

Depth Drilled 114 Feet Depth Cased 114 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6	Inches	50	Feet	114	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	114

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 108 feet to 112 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☐ Yes ☒ No
From feet to feet

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

9. WATER LEVEL
Static water level 22' feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (CONTRACTOR)
Address P. O. BOX 888 (CONTRACTOR)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed [signature]
By driller performing actual drilling on site or contractor
Date JUNE 20, 2005

(Rev 12/01) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. - (214) 340-9429 - FormsOnADisk.com