


STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 98354
 Permit No. _____
 Basin 794



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **55737**

1. OWNER **Rita Cannizzaro** ADDRESS AT WELL LOCATION **120 Cobalt Red rock**
 MAILING ADDRESS **P.O. Box 60453**
Reno, NV 89506

2. LOCATION **SE 1/4 SE 1/4 Sec. 12 T 22N** N/S R **18E E** **Washoe** County
 PERMIT NO. **079-371-23** Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
D.G.		3	18	15
Weatherd granite		18	43	25
Clay streak		43	45	2
Weathered granite		45	81	36
Gray granite		81	155	74
Weatherd granite with clay streaks		155	180	25
Fracture		180	181	1
White granite		181	220	39
Fracture		220	221	1
White weatherd granite		221	290	69
Pink to weatherd granite		290	335	45
Soft zone		335	336	1
Weatherd granite		336	490	154
Fracture		490	491	1
Weatherd granite hard		491	544	53
Soft zone		544	545	1
Weatherd granite		545	654	109
Gray granite hard		654	685	31
Soft zone		685	688	3
Black volcanic rock		688	696	8
Weatherd granite		696	798	102
Fracture		798	799	1
Weatherd granite		799	848	49
Soft zone	x	848	852	4
Weatherd granite		852	936	84
Fracture	x	936	937	1
Weatherd granite		937	975	38

Washoe County Well Permit # **WL 050108**

8. WELL CONSTRUCTION
 Depth Drilled **975** Feet Depth Cased **975** Feet
 HOLE DIAMETER (BIT SIZE)

10 5/8	Inches	From 0	Feet	To 50	Feet
8 5/8	Inches	From 50	Feet	To 975	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	975

Perforations:
 Type perforation **Machine cut**
 Size perforation **3/32 x 3**

From	815	feet to	835	feet
From	855	feet to	875	feet
From	895	feet to	915	feet
From	935	feet to	955	feet
From		feet to		feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From **50** feet to **975** feet

9. WATER LEVEL
 Static water level **700** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **Cool** °F Quality **Not tested**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Bruce MacKay Pump & Well Service, Inc.** Contractor
 Address **1600 Mt. Rose Hwy** Contractor
Reno, NV 89511
 Nevada contractor's license number issued by the State Contractor's Board **23096**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **923**
 Signed R. Bruce MacKay
 By driller performing actual drilling on-site or contractor
 Date **7/7/2005**

Date started **6/21/2005**, 19
 Date completed **7/6/2005**, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	17.5	12	3

RECEIVED
 05 JUL 12 PM 2:18
 STATE ENGINEERS OFFICE