WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98378
Permit No.
Basin 089

NOTICE OF INTENT NO. 55313

1. OWNER Brad & Vicky Cralle
MAILING ADDRESS 3035 Eastlake Blvd.
Washoe Valley, NV 89704

ADDRESS AT WELL LOCATION 3035 Eastlake Blvd.

2. LOCATION NE 1/4 SE 1/4 Sec. 31 T 17N N/S R 20E E Washoe County
PERMIT NO. Issued by Water Resources
Parcel No. 50-401-13
Subdivision Name

3. **WORK PERFORMED**
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Granite		120	200	80
Granite Fractured	x	200	275	75
Washoe County Well Permit # WL 050187				

RECEIVED 05 AUG 1 8 PM 2:52 WATER RESOURCES OFFICE

Date started 7/28/2005 , 19__
Date completed 7/28/2005 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+		3

8. **WELL CONSTRUCTION**
Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
5 5/8	Inches	120	Feet	275	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10.79	.188	95	275

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 195 feet to 275 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. **WATER LEVEL**
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality not tested

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 8/1/2005

USE ADDITIONAL SHEETS IF NECESSARY