

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54323

1. OWNER Lana Clarke ADDRESS AT WELL LOCATION #110, 30 CARNS CIRCLE  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 SE 1/4 Sec. 28 T. 11 N/S R. 24 E Lyon Co County  
 PERMIT NO. 9-121-03 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Silt + Sand</u>		<u>0</u>	<u>18'</u>	<u>18'</u>
<u>Clay Tan</u>		<u>18</u>	<u>310'</u>	<u>18'</u>
<u>Gravel + Clay</u>		<u>310</u>	<u>78'</u>	<u>42'</u>
<u>Cobbles + Clay</u>		<u>78</u>	<u>142'</u>	<u>64'</u>
<u>Gravel + Clay</u>		<u>142</u>	<u>168'</u>	<u>26'</u>
<u>Tan Brown Clay</u>		<u>168</u>	<u>280'</u>	<u>112'</u>
<u>Gravel + Clay</u>		<u>280</u>	<u>310'</u>	<u>30'</u>
<u>Gravel</u>		<u>310</u>	<u>340'</u>	<u>30'</u>

8. WELL CONSTRUCTION  
 Depth Drilled 340 Feet Depth Cased 340 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 7/8 Inches +1 Feet To 340 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>Steel</u>	<u>1/8</u>	<u>+1</u>	<u>20</u>
<u>6 7/8</u>	<u>PVC</u>	<u>5/16</u>	<u>20</u>	<u>340</u>

Perforations:  
 Type perforation Sawed  
 Size perforation 1/8" x 4"  
 From 300 feet to 340' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 60'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 60 feet to 340' feet

9. WATER LEVEL  
 Static water level 110' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Clear

Date started 10/5/05, 20\_\_\_\_  
 Date completed 10/7/05, 20\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Air Lifted</u>	<u>35 Gpm</u>	<u>3 lbs</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Seach Drilling Inc. Contractor  
 Address PO Box 599 Contractor  
Silver Springs, NV  
 Nevada contractor's license number issued by the State Contractor's Board 31841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 10/28/05