WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48401
Permit No.
Basin 092A

NOTICE OF INTENT NO. 56401

1. OWNER Coldsprings Properties
MAILING ADDRESS 3675 Lakeside Dr.
Reno, NV 89509

ADDRESS AT WELL LOCATION ~~3675 Lakeside Dr. Reno~~
Lot #9 Coldsprings Way, Reno

2. LOCATION NW 1/4 NE 1/4 Sec. 19 T 21N N/S R 19E E Washoe County
PERMIT NO. Issued by Water Resources
087-041-04 Parcel No.
Subdivision Name

3. **WORK PERFORMED**
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
On this date we abandoned a 6" x 200' well by perforating with mills knife at 4 around and at one foot intervals from 115' to 50', then we pumped neat cement, mixed 5.2 gallons of water per sack. We pumped using tremie pipe from the bottom of the well to the top.				

Date started 10/26/2005 , 19__
Date completed 10/26/2005 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	200

Perforations:
Type perforation 3/32 x 3
Size perforation

From 115 feet to 125 feet
From 145 feet to 155 feet
From 175 feet to 195 feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. **WATER LEVEL**
Static water level 92 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality Not tested

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2299
Signed R. Bruce MacKay (By driller performing actual drilling on site or contractor)
Date 10/27/2005

USE ADDITIONAL SHEETS IF NECESSARY