WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98402
Permit No.
Basin 189

NOTICE OF INTENT NO. 51404

1. OWNER John & Julie Gianoli
MAILING ADDRESS 1180 So. Bell Avenue
S.W. Ely, Nevada 89301

ADDRESS AT WELL LOCATION 1 Mile North of Sacramento Pass

2. LOCATION ~~SE~~ ¼ ~~NW~~ ¼ Sec. 21 T. 15 N/~~S~~ R. 68 E. White Pine County
PERMIT NO. 72643 (Issued by Water Resources) NE 4 B APN 12-070-07 (Parcel No.) The Meadows (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Sand & Boulders		2	13	11
Altered Limestone		13	55	42
Quartz & Limestone		55	65	10
Altered Limestone		65	98	33
Fractured Limestone	X	98	105	7
Altered Limestone		105	142	37
Fractured Limestone	X	142	146	4
Fractured Limestone &		146		
some clay			151	5
Altered Limestone		151	172	21
Fractured Limestone	X	172	176	4
Altered Limestone		176	203	27

2005 NOV 29 PM 12:40

Date started October 11, 2005
Date completed November 10, 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	98	1

8. WELL CONSTRUCTION
Depth Drilled 203 Feet Depth Cased 203 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	203 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	203

Perforations:
Type perforation Factory
Size perforation 1/8" X 2½" 6 Rows
From 103 feet to 203 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 Feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 203 feet

9. WATER LEVEL
Static water level 102 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, Nevada 89301

Nevada contractor's license number issued by the State Contractor's Board 14790

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793

Signed Rick Lewis By Jerald D. Christiansen
(By driller performing actual drilling on site or contractor)
Date November 14, 2005

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627