

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54126

1. OWNER Collins & Sons Const. ADDRESS AT WELL LOCATION SOTTO
260 Sutto Rd.
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 NE 1/4 Sec 8 T 16 N/S R. 22 E. Lyon County
 PERMIT NO. _____ Issued by Water Resources Parcel No. 016-352-12 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	8'	8'
Broken Clay		8'	25'	17'
DG		25'	55'	30'
Grey clay		55'	70'	15'
DG		70'	86'	16'
Lgy Sand		86'	120'	34'
Lgy Gravel		120'	160'	40'
Grey Sand Clay w/ Gravel		160'	165'	5'
Gravel		165'	180'	15'
Lgy Gravel		180'	200'	20'

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 50"
 11" Inches _____ Feet _____
 _____ Inches _____ Feet _____
 _____ Inches _____ Feet _____
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>.188"</u>	<u>+1</u>	<u>20'</u>
<u>6 3/8</u>		<u>SIDR 21</u>	<u>20'</u>	

Perforations:
 Type perforation Grinder cut
 Size perforation 1/8
 From 120 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to _____ feet

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature 60 °F Quality _____

RECEIVED
 OCT 04 2005

STATE ENGINEER'S OFFICE

Date started 6-27-05 2005
 Date completed 6-28-05 2005

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>207</u>	<u>NA</u>	<u>4 hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BLAIN DRILLING & PUMP CO. INC.
 Address P.O. Box 1255 Carson City, NV 89702
 Nevada contractor's license number issued by the State Contractor's Board 46497
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 213P
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6-29-05