

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54312

1. OWNER Best Energy LLC ADDRESS AT WELL LOCATION 14900 Bangs Rd
 MAILING ADDRESS _____
 2. LOCATION 3W 1/4 NW 1/4 Sec. 23 T. 19 N/S R. 26 E Churchill Co County
 PERMIT NO. 71713 Issued by Water Resources Parcel No. 007-021-78 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other well

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand & clay</u>		<u>0</u>	<u>42'</u>	<u>42'</u>
<u>Volcanic Rock</u>		<u>42'</u>	<u>250'</u>	<u>208'</u>
<u>Volcanic Rock with fractures</u>	<input checked="" type="checkbox"/>	<u>250'</u>	<u>300'</u>	<u>50'</u>

8. WELL CONSTRUCTION
 Depth Drilled 300' Feet Depth Cased 300' Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 5/8 Inches _____ Feet 60 Feet
8 3/4 Inches 60 Feet 300' Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>		<u>.188</u>	<u>71</u>	<u>300</u>

Perforations:
 Type perforation 1/8 x 3 Sawn
 Size perforation 8 Rows
 From _____ feet to _____ feet
 From 260' feet to 300' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100' feet to 300' feet

9. WATER LEVEL
 Static water level 53' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold F Quality clean

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Jack Drilling Inc. Contractor
 Address PO Box 599 Contractor
Behm Springs NV.
 Nevada contractor's license number issued by the State Contractor's Board 31841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
 Signed Patrick J. Peck
 By driller performing actual drilling on site or contractor
 Date 10/19/05

Date started 9/16/05, 20_____
 Date completed 9/25/05, 20_____
 RECEIVED
 2005 OCT 12 AM 11:10
 STATE ENGINEERS OFFICE

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>air lifted</u>	<u>50 Gpm</u>	<u>from</u>	
<u>200' feet.</u>	<u>3 hrs.</u>		