

4 wells
 STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 98440
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 28799

1. OWNER Campbell Concrete Inc. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 5201 Polaris Ave 5201 Polaris Ave
Las Vegas, NV 89118 Las Vegas, NV 89118
 2' LOCATION SW 1/4 NW 1/4 Sec. 29 T. 21 N. R. 61 E. Clark County
 PERMIT NO. 162-29-204-010 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE Cable Rotary RVC Air Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------------------|--------------|-----------|-----------|------------|
| <u>Silty Sand w/ Gravel</u> | | <u>0</u> | <u>4</u> | <u>4</u> |
| <u>Silty Clay</u> | | <u>4</u> | <u>6</u> | <u>2</u> |
| <u>Caliche</u> | | <u>6</u> | <u>9</u> | <u>3</u> |
| <u>Silty Clay</u> | | <u>9</u> | <u>27</u> | <u>18</u> |
| <u>Caliche</u> | | <u>27</u> | <u>30</u> | <u>3</u> |
| <u>Silty sand</u> | <u>33</u> | <u>30</u> | <u>45</u> | <u>15</u> |

**DCNR/DWR
 RECEIVED
 JAN 4 - 2006
 LAS VEGAS OFFICE**

8. WELL CONSTRUCTION
 Depth Drilled 45 Feet Depth Cased 45 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 Inches To 45 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|----------------------|---------------------|-------------------------|-------------|-----------|
| <u>2" SCH 40 PVC</u> | | | <u>0</u> | <u>25</u> |

Perforations:
 Type perforation Factory Slotted
 Size perforation .020
 From 25 feet to 45 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 22
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 22 feet to 45 feet

9. WATER LEVEL
 Static water level 33 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WDC Exploration & Wells Contractor
 Address 570 Corinthian Way Contractor
N. Las Vegas, NV 89030
 Nevada contractor's license number issued by the State Contractor's Board 0012852
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 2057
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 12-28-05

Date started 8-16-2005
 Date completed 8-20-2005

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |