COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98444
Permit No.
Basin 105

NOTICE OF INTENT NO. 52336

1. OWNER ARTHUR ARP
MAILING ADDRESS 1976 LACEY CT
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 1976 LACEY CT
GARDNERVILLE, NV 89410

2. LOCATION SW ¼ SE ¼ Sec 24 T 12 N R 20 E DOUGLAS County

PERMIT NO. NE (Issued by Water Resources) 1220-24-701-039 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 8 5/8 WELL APP.		+2	180	180
FRACTURED OBSIDIAN GRAVELS		180	205	25
COURSE GRAVELS		205	243	38
BROWN CLAY		243	251	8
FRACTURED GRAVELS OBSIDIAN SANDS	XX	251	280	29

RECEIVED 2005 OCT 13 AM 11:04 STATE ENGINEERS OFFICE

Date started 9/6, 20 05
Date completed 9/8, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	30	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 280 ~~100'~~ Feet Depth Cased 280 ~~120'~~ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
7 7/8 Inches	180 Feet	280 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	160	280

Perforations:
Type perforation FACTORY MIILL SLOT
Size perforation 3 X 3/32
From 240 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No Seal Type:
Depth of Seal N/A ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 160 feet below land surface
Artesian flow G.P.M 20 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89410
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 9/12/05

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429