

2 wells

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 98452
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28824

1. OWNER: STEWART ENVIRONMENTAL
MAILING ADDRESS: 9101 W. SARADA AVE SUITE 105-B32 LAS VEGAS, NV 89117
ADDRESS AT WELL LOCATION: 60176 LAS VEGAS BLVD. S. LAS VEGAS, NV 89118
2. LOCATION: NE 1/4 SW 1/4 Sec. 32 T. 21 N. R. 61 E. CLARK County
PERMIT NO.: 162-32-802-052
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED: New Well Replace Recondition Deepen Abandon Other
4. PROPOSED USE: Domestic Municipal/Industrial Irrigation Monitor Test Stock
5. WELL TYPE: Cable Rotary RVC Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Type II SANDY CLAY (GRAVEL)		0.0	3.0	3.0
CLAY w/ Silt		3.0	30.0	27.0
SANDY Silt w/ GRAVEL		30.0	55.0	25.0
		55.0	80.0	25.0

CONFIDENTIAL
RECEIVED
DEC 23 2005
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled: 80.0 Feet Depth Cased: 80.0 Feet
HOLE DIAMETER (BIT SIZE)
From 11 Inches To 10.0 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	SCH 40	PVC	0.0	80.0

Perforations:
Type perforation: MACHINE SLOTTED
Size perforation: .020
From 60.0 feet to 80.0 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal: 2'
Placement Method: Pumped Poured
Gravel Packed: Yes No
From 55.0 feet to 80.0 feet

9. WATER LEVEL
Static water level: 68.2 feet below land surface
Artesian flow: G.P.M. P.S.I.
Water temperature: °F Quality:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name: WDC Exploration & Wells Contractor
Address: 570 CANTONIAN N. LAS VEGAS, NV 89030 Contractor

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

Nevada contractor's license number issued by the State Contractor's Board: 0012852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 2202
Signed: [Signature] By driller performing actual drilling on site or contractor
Date: 12-22-05