

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 98458  
 Permit No. \_\_\_\_\_  
 Basin 103  
 NOTICE OF INTENT NO. 52338

PRINT OR TYPE ONLY

1. OWNER TERRY BUNKOWSKI  
 MAILING ADDRESS DAYTON, NV 89403  
 ADDRESS AT WELL LOCATION 294 RIVER RD DAYTON, N V89403

2. LOCATION SW 1/4 NW 1/4 Sec 5 T 16 N R 21 E  
 PERMIT NO. SW NF 16-311-37  
 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 LYON County

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
HARDPAN CLAY		0	3	3
SMALL GRAVELS		3	5	2
LARGE GRAVELS		5	23	18
BOULDERS AND COBBLES		23	38	15
BROWN CLAY AND SANDS		38	51	13
CLAY AND SMALL GRAVELS		51	110	59
RACTURED GRAVELS				
SMALL RIVER ROCK	XXX	110	160	50

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 3/4 Inches To 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	160

Perforations:  
 Type perforation SAW CUT  
 Size perforation 3X3/32  
 From 140 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 160 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ 25 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 30+ P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING  
 (CONTRACTOR)  
 Address # 20 KIT KAT DRIVE  
 (CONTRACTOR)  
CARSON CITY, N V89706  
 Nevada contractor's license number issued by the State Contractor's Board 0055548  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2156  
 Signed Rick Crane  
 By driller performing actual drilling on site or contractor  
 Date 10/6/05

Date started 9/20, 20 05  
 Date completed 9/23, 20 05

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>30+</u>	<u>35</u>	<u>3 HRS</u>	

RECEIVED  
 2005 OCT 13 AM 11:03  
 STATE ENGINEERS OFFICE