COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98459
Permit No.
Basin 105

NOTICE OF INTENT NO. 52342

1. OWNER SCOTT SMITH CONSTRUCTION
MAILING ADDRESS 1324 TOIYABE AVE
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 3668 CHEROKEE DR
MINDEN, NV 89403

2. LOCATION SW ¼ NE ¼ Sec 1 T 14 N R 19 E DOUGLAS County

PERMIT NO. NE SE (Issued by Water Resources) 1419-01-701-020 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SANDS		0	3	3
SOFT SANDS		3	8	5
DG SANDS		8	73	65
BROWN CLAY		73	105	32
HARDPAN DG SANDS		105	134	29
FRACTURED DG SAND	X	134	160	26
COURSE DG GRAVELS	XX	160	200	40

RECEIVED 2005 OCT 13 AM 11:03 STATE ENGINEERS OFFICE

Date started 10/7, 20 05
Date completed 10/8, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	38	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 sdr21	4.06	.216	20	200

Perforations:
Type perforation SAW CUT
Size perforation 3 X 3/32
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured
Gravel Packed: ☒ Yes ☐ No
From 60 feet to 200 feet

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 85 feet below land surface
Artesian flow G.P.M 25 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, N V89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 10/10/05

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429