COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98460
Permit No.
Basin 105

NOTICE OF INTENT NO. 52340

1. OWNER CHRIS SHEERIN
MAILING ADDRESS
ADDRESS AT WELL LOCATION 227 GOA WAY
GARDNERVILLE, NV 89410

2. LOCATION ~~SW~~ ¼ ~~SW~~ ¼ Sec 3 T 12 N R 19 E DOUGLAS County
PERMIT NO. NW SW (Issued by Water Resources) | 1219-03-002-103 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LARGE DG BOULDERS		0	26	26
COUSE DG SANDS		26	63	37
HARD PAN DG		63	110	47
HARD GRANITE		110	163	53
SANDY CLAY		163	190	27
DG SANDS		190	198	8
VERY SANDY CLAY		198	239	41
FRACTURED GRANITE		239	260	21

RECEIVED 2005 OCT 13 AM 11:03 STATE ENGINEERS OFFICE

Date started 9/30, 20 05
Date completed 10/3, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	50	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	260 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 sdr21	4.06	.216	20	260

Perforations:
Type perforation SAW CUT
Size perforation 3X32
From 220 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 260 feet

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M 25+ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITYU, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed [signature] By driller performing actual drilling on site or contractor
Date 10/8/05

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429